SITE DEVELOPMENT PLANS

PREPARED FOR

NORTHERN PASS TRANSMISSION, LLC PROPOSED FRANKLIN CONVERTER STATION


SOUTH MAIN STREET, FRANKLIN, NH 03235

OWNER:



ENGINEER:





O 2000' 4000'

SCALE IN FEET

OCTOBER 1, 2015

FOR PERMITTING
PURPOSES ONLY
NOT FOR CONSTRUCTION

	DRAWING INDEX						
DRAWING	DESCRIPTION						
CVR	COVER SHEET						
G001	GENERAL NOTES AND LEGEND						
C100	SITE LAYOUT PLAN						
C101	GRADING PLAN						
C102	EROSION AND SEDIMENTATION CONTROL PLAN						
C103	PLANTING PLAN						
C104	STORMWATER SYSTEM PLAN						
C200	ACCESS ROAD PROFILES						
C300	SITE CROSS SECTIONS						
C301	SITE CROSS SECTIONS						
C500	EROSION & SEDIMENTATION CONTROL NOTES						
C501	EROSION & SEDIMENTATION CONTROL DETAILS						
C502	EROSION & SEDIMENTATION CONTROL DETAILS						
C503	CONSTRUCTION DETAILS						
C504	CONSTRUCTION DETAILS						
C505	CONSTRUCTION DETAILS						
C506	CONSTRUCTION DETAILS						
C507	CONSTRUCTION DETAILS						
C508	CONSTRUCTION DETAILS						

Call Dig Safe before you dig.



NEW HAMPSHIRE STATE LAW REQUIRES HOMEOWNERS AND CONTRACTORS TO CONTACT DIG SAFE, BY DIALING 8-1-1 AT LEAST THREE BUSINESS DAYS BEFORE BEGINNING ANY DIGGING OR EXCAVATION PROJECT. WHEN DIG SAFE RECEIVES A CALL, THE HOMEOWNER OR CONTRACTOR MUST WAIT 72 BUSINESS HOURS. DURING THIS TIME, UTILITY REPRESENTATIVES RESPOND TO MARK THEIR LINES WITHIN YOUR PRE-MARKED AREA. ALL INFORMATION REGARDING DIG SAFE RULES AND REGULATIONS CAN ALSO BE FOUND AT www.digsafe.com.

7	BHIAN BHIAN BHIAN BAKIDOVINCH - E
Th	s document has been digitally sealed

Oct 5 2015

Z:\CLIENTS\TND\NUSC\58466_NPT\DESIGN\SUBSTATION\500-FRANKLIN\CADD\CIVIL-SITE\NPTT501-CVR.DWG 9/30/2015 5:49 PM RLREED

DES: RLR CHK: JJS
DRW: KRB APR: BSS
TOWN:
FRANKLIN, NH

Business

RANKLIN STATION COVER SHEET

SHEET 1 OF 19

BACKGROUND NOTES:

- BACKGROUND INFORMATION BASED ON "EXISTING CONDITIONS PLAN" BY CHA DESIGN/CONSTRUCTION SOLUTIONS DATED 12/02/2013.
- 2. ELEVATIONS. CONTOURS AND BENCHMARKS ARE BASED ON NAVD 1988 VERTICAL DATUM.
- 3. HORIZONTAL LOCATIONS ARE BASED ON NEW HAMPSHIRE STATE PLANE COORDINATE SYSTEM NAD 83.
- 4. THERE ARE DELINEATED WATERCOURSES LOCATED ONSITE. REFER TO WETLANDS, RIVERS, STREAMS AND VERNAL POOLS DELINEATION REPORT BY NORMANDEAU ENVIRONMENTAL CONSULTANTS DATED NOVEMBER 22, 2013.
- 5. THE SITE IS LOCATED WITHIN FEMA ZONE 'X' FLOOD ZONE AREAS DETERMINED TO BE OUTSIDE THE 0.2% ANNUAL CHANCE FLOODPLAIN ACCORDING TO THE FEDERAL EMERGENCY MANAGEMENT AGENCY FLOOD INSURANCE RATE MAP NUMBER 33013CO169E, DATED APRIL 19,
- 6. PROPERTY AREA = 118.457 ACRES, NPDES/LIMIT OF DISTURBANCE (LOD) AREA TOTAL = 15.875 ACRES.

GENERAL NOTES:

- 1. GENERAL NOTES SHALL APPLY TO THE SITE DEVELOPMENT PLANS THROUGHOUT. REFER TO INDIVIDUAL SHEETS FOR SHEET SPECIFIC NOTES.
- 2. CONTRACTOR(S) TO TAKE AND VERIFY ALL DIMENSIONS AND CONDITIONS OF THE WORK AND BE RESPONSIBLE FOR COORDINATION OF SAME. FIELD VERIFY ALL EXISTING CONDITIONS PRIOR TO START OF WORK.
- ENGINEER ASSUMES NO RESPONSIBILITY AS TO THE CONTENT OF THE EXISTING CONDITIONS PLAN INCLUDING BUT NOT LIMITED TO LOCATION, SIZE, AND ELEVATIONS OF UTILITIES AND STRUCTURES NOT VISIBLE AND WHERE TAKEN FROM PLANS BY OTHERS.
- 4. EXISTING CONDITIONS SURVEY INFORMATION ON EXISTING UTILITIES AND STORM DRAINAGE SYSTEMS HAS BEEN COMPILED FROM AVAILABLE INFORMATION INCLUDING UTILITY COMPANY AND MUNICIPAL RECORD MAPS AND/OR FIELD SURVEY AND IS NOT GUARANTEED CORRECT OR COMPLETE. UTILITIES AND STORM DRAINAGE SYSTEMS ARE SHOWN TO ALERT THE CONTRACTOR TO THEIR PRESENCE AND THE CONTRACTOR IS SOLELY RESPONSIBLE FOR DETERMINING ACTUAL LOCATIONS AND ELEVATIONS OF ALL UTILITIES AND STORM DRAINAGE SYSTEMS INCLUDING SERVICES PRIOR TO DEMOLITION OR CONSTRUCTION. THE CONTRACTOR SHALL CONTACT "DIGSAFE" PRIOR TO COMMENCEMENT OF WORK AT "811" AND VERIFY ALL UTILITY AND STORM DRAINAGE SYSTEM LOCATIONS.
- 5. THE CONTRACTOR SHALL VERIFY ALL EXISTING SITE AND BUILDING CONDITIONS IN THE FIELD AND CONTACT THE OWNER AND ENGINEER IF THERE ARE ANY QUESTIONS AND/OR CONFLICTS REGARDING THE SITE DEVELOPMENT PLANS AND/OR EXISTING FIELD CONDITIONS PRIOR TO CONSTRUCTION. REFER TO THE PROJECT SPECIFICATIONS MANUAL FOR ADDITIONAL INFORMATION. SHOULD ANY UNCHARTED OR INCORRECTLY CHARTED, EXISTING PIPING OR OTHER UTILITY BE UNCOVERED DURING EXCAVATION, INFORM THE OWNER AND CONSULT THE CIVIL ENGINEER IMMEDIATELY FOR DIRECTIONS BEFORE PROCEEDING FURTHER WITH WORK IN THIS AREA.
- 6. ALL CONSTRUCTION SHALL COMPLY WITH PROJECT SPECIFICATION MANUAL.EVERSOURCE STANDARDS AND SPECIFICATIONS, AND THESE PLANS. IF SPECIFICATIONS ARE IN CONFLICT, THE MORE STRINGENT SPECIFICATION SHALL APPLY. ALL CONSTRUCTION SHALL BE PERFORMED IN ACCORDANCE WITH ALL APPLICABLE OSHA, FEDERAL, STATE AND LOCAL REGULATIONS. INCLUDING BUT NOT LIMITED TO THE FOLLOWING:
 - a. NEW HAMPSHIRE STORMWATER MANUAL, VOLUMES 1, 2 & 3, DECEMBER 2008.
 - b. NEW HAMPSHIRE DEPARTMENT OF TRANSPORTATION MANUAL ON DRAINAGE DESIGN FOR HIGHWAYS. REVISION DATE APRIL 1998.
 - c. NEW HAMPSHIRE DEPARTMENT OF TRANSPORTATION STANDARD PLANS AND SPECIFICATIONS (2010).
 - d. EVERSOURCE BEST MANAGEMENT PRACTICES MANUAL (TO BE FURTHER DEVELOPED).
 - e. EVERSOURCE STANDARD SPECIFICATIONS (10-24-2014).
- 7. DO NOT INTERRUPT EXISTING SERVICING UTILITIES AND FACILITIES OCCUPIED AND USED BY THE OWNER OR OTHERS DURING OCCUPIED HOURS EXCEPT WHEN SUCH INTERRUPTIONS HAVE BEEN AUTHORIZED IN WRITING BY THE OWNER, THE LOCAL MUNICIPALITIES, THE UTILITY PROVIDER, AND ANY APPLICABLE REGULATORY AGENCY. INTERRUPTIONS SHALL ONLY OCCUR AFTER ACCEPTABLE TEMPORARY SERVICE HAS BEEN PROVIDED.
- THE CONTRACTOR SHALL PROVIDE RECORD AS-BUILT DRAWINGS OF ALL CONSTRUCTION IN ACCORDANCE WITH OWNER AND REGULATORY AGENCY REQUIREMENTS (INCLUDING UNDERGROUND UTILITIES) TO THE OWNER AT THE END OF CONSTRUCTION.
- WRITTEN DIMENSIONS HAVE PRECEDENCE OVER SCALED DIMENSIONS. THE CONTRACTOR SHALL USE CAUTION WHEN SCALING

- PLANS. IN CASE OF CONFLICT BETWEEN PLAN SET AND ANY OTHER DRAWING AND/OR SPECIFICATION, THE ENGINEER SHALL BE NOTIFIED IMMEDIATELY FOR CLARIFICATION.
- IF A CONFLICT ARISES BETWEEN PLANS. SPECIFICATIONS. AND/OR DETAILS. THE ENGINEER SHALL BE NOTIFIED IMMEDIATELY FOR CLARIFICATION.
- 11. THE CONTRACTOR SHALL ABIDE BY ALL OSHA, FEDERAL, STATE, AND LOCAL REGULATIONS IN ALL INSTANCES AND WHEN OPERATING CRANES, BOOMS, HOISTS, ETC. IN CLOSE PROXIMITY TO OVERHEAD ELECTRIC LINES. IF CONTRACTOR MUST OPERATE EQUIPMENT CLOSE TO ELECTRIC LINES, CONTACT POWER COMPANY TO MAKE ARRANGEMENT FOR PROPER SAFEGUARDS. ANY UTILITY COMPANY FEES SHALL BE PAID FOR BY THE CONTRACTOR.
- 12. THE ENGINEER IS NOT RESPONSIBLE FOR SITE SAFETY MEASURES TO BE EMPLOYED DURING CONSTRUCTION. THE ENGINEER HAS NO CONTRACTUAL DUTY TO CONTROL THE SAFEST METHODS OR MEANS OF THE WORK, JOB SITE RESPONSIBILITIES, SUPERVISION OR TO SUPERVISE SAFETY AND DOES NOT VOLUNTARILY ASSUME ANY SUCH DUTY OR RESPONSIBILITY.
- 13. ALL NOTES AND DIMENSIONS DESIGNATED "TYPICAL" OR "(TYP.)" APPLY TO ALL LIKE OR SIMILAR CONDITIONS THROUGHOUT THE PROJECT.
- 14. ALTERNATIVE METHODS AND PRODUCTS OTHER THAN THOSE SPECIFIED MAY BE USED IF SUBMITTED, REVIEWED, AND APPROVED BY THE OWNER, ENGINEER, AND APPROPRIATE REGULATORY AGENCY PRIOR TO CONSTRUCTION.
- 15. THE CONTRACTOR SHALL SUBMIT SHOP DRAWINGS OF ALL PRODUCTS AND MATERIALS PER PLANS AND SPECIFICATIONS TO THE OWNER AND ENGINEER FOR REVIEW AND APPROVAL PRIOR TO ORDERING. FABRICATION, OR DELIVERY TO THE SITE. FOR EACH SUBMITTAL, ALLOW A MINIMUM OF 14 WORKING DAYS FOR REVIEW.
- 16. THE CONTRACTOR SHALL RESTORE ANY DRAINAGE STRUCTURE, PIPE, UTILITY, PAVEMENT, CURBS, SIDEWALKS, LANDSCAPED AREAS OR SIGNAGE AND OTHER INCIDENTAL DISTURBANCES AND DAMAGES DURING CONSTRUCTION TO THEIR ORIGINAL CONDITION OR BETTER. AS APPROVED BY THE OWNER, ENGINEER AND REGULATORY AGENCY
- 17. THE CONTRACTOR SHALL COMPLY WITH 29 CFR PART 1926 FOR EXCAVATION TRENCHING AND TRENCH PROTECTION REQUIREMENTS.
- 18. NO CONSTRUCTION OR DEMOLITION SHALL BEGIN UNTIL APPROVAL OF THE FINAL PLANS IS GRANTED BY ALL GOVERNING AND REGULATORY AGENCIES.
- 19. DEMOLITION OF EXISTING CONDITIONS INCLUDING BUT NOT LIMITED TO BUILDINGS, STRUCTURES, PAVEMENT, WELLS, SEPTIC, SANITARY SEWER, FENCES, TREES, ETC. SHALL BE PER THE DIRECTION OF EVERSOURCE AND SHALL BE IN ACCORDANCE WITH ALL APPLICABLE LOCAL, STATE, AND FEDERAL REGULATIONS.
- 20. PERMANENT BENCHMARKS SHALL BE INSTALLED UPON COMPLETION OF CLEARING.
- 21. ELECTRICAL STATION COMPONENTS, UNDERGROUND TRANSMISSION LINES, OVER HEAD TRANSMISSION LINES AND THEIR FOUNDATIONS DEPICTED HEREIN ARE FOR REFERENCE ONLY.
- 22. ANY CLEARED AND EXCAVATED MATERIALS WHICH ARE SUSPECTED OF BEING ENVIRONMENTALLY POLLUTED. CONTAMINATED. OR IMPACTED SHALL BE STOCKPILED ON-SITE ON TOP OF POLYETHYLENE SHEETING AND COVERED WITH POLYETHYLENE SHEETING. THE OWNER AND ENGINEER SHALL BE IMMEDIATELY INFORMED UPON ENCOUNTERING THIS MATERIAL. STORAGE, TESTING, TREATMENT, REMOVAL, AND DISPOSAL OF ENVIRONMENTALLY POLLUTED, CONTAMINATED, OR IMPACTED MATERIAL SHALL BE IN ACCORDANCE WITH APPLICABLE LOCAL, STATE, AND FEDERAL REGULATIONS.
- 23. CONTRACTOR SHALL TAKE PRECAUTIONS TO ENSURE NO DISTURBANCE BEYOND THE DEPICTED LIMIT OF DISTURBANCE.
- 24. THE CONTRACTOR SHALL ESTABLISH BEST MANAGEMENT PRACTICES FOR BLASTING OF BEDROCK IN ACCORDANCE WITH THE NHDES PUBLICATION WD-10-12 "ROCK BLASTING AND WATER QUALITY MEASURES THAT CAN BE TAKEN TO PROTECT WATER QUALITY AND MITIGATE IMPACTS", 2010. IF THE BLAST ROCK VOLUME GENERATED IS GREATER THAN 5,000 CUBIC YARDS, THE CONTRACTOR SHALL DEVELOP A GROUNDWATER MONITORING PROGRAM FOR SUBMISSION TO THE OWNER AND ENGINEER. BLASTING SHALL NOT COMMENCE UNTIL THESE REQUIREMENTS ARE APPROVED BY THE NHDES, AS REQUIRED.
- 25. PROPOSED STORM DRAINAGE SYSTEM SHALL BE HS-20 RATED.

	PROPERTY LINE
	ADJOINING PROPERTY LINE
	RIGHT OF WAY LINE
	EASEMENT LINE
	MAJOR CONTOUR
381	MINOR CONTOUR
	TREELINE
OHW	OVER HEAD WIRE
	STOCKADE FENCE
O — O — O —	CHAIN LINK FENCE
	WETLANDS LINE
	STREAM OR WATERWAY
000000000	STONEWALL
• WF600-9	WETLAND FLAG
O IP	IRON PIPE
⊡ CB/DH	CONCRETE BOUND WITH DRILL HOLE
□ SB/DH	STONE BOUND WITH DRILL HOLE
	SURVEY CONTROL POINT
	UTILITY POLE

PROPOSED LEGEND	
385———	MAJOR CONTOUR
381	MINOR CONTOUR
······	TREELINE
× × ×	PERIMETER FENCE
• • • • •	GUIDERAIL
—	SILT FENCE
	CONSTRUCTION FENCE
	LIMIT OF STONE SURFACING
LOD —LOD —	LIMIT OF DISTURBANCE
	STORMWATER SWALE
— — — UD — — — — UD — — —	UNDERDRAIN PIPE
	STORM SEWER PIPE
	MANHOLE
	OUTLET CONTROL STRUCTURE
	FLARED END SECTION
o co	CLEANOUT
330.50	SPOT ELEVATION
	RIP RAP
	GRAVEL STONE SURFACING
	BITUMINOUS CONCRETE PAVEMENT

|--|

ACP	ASBESTOS CEMENT PIPE	LBS	POUNDS
APT	ANGLE POINT	LF	LINEAR FOOT
ASTM	AMERICAN SOCIETY FOR TESTING AND MATERIALS	LG	WALL HIGH GRADE
BIT	BITUMINOUS CONCRETE	LOD	LIMIT OF DISTURBANCE
BLDG	BUILDING	MAX	MAXIMUM
BM	BENCH MARK	MFR	MANUFACTURER
BW	BOTTOM OF WALL	MH	MANHOLE
СВ	CATCH BASIN	MIN	MINIMUM
CATV	CABLE TELEVISION	Ν	NORTHING
CI	CAST IRON PIPE	NO	NUMBER
CIC	CAST IRON COVER	NOM	NOMINAL
ą.	CENTERLINE	OC	ON CENTER
CL	CENTERLINE	ocs	OUTLET CONTROL STRUCTURE
CLF	CHAIN LINK FENCE	OD	OUTSIDE DIMENSION
CLR	CLEAR	PC	POINT OF CURVATURE
CMP	CORRUGATED METAL PIPE	POB	POINT OF BEGINNING
CO	CLEANOUT	PIV	POST INDICATOR VALVE
CONC	CONCRETE	PRC	POINT OF REVERSE CURVATURE
COR	CORNER	PSI	POUNDS PER SQUARE INCH
CTRS	CENTERS	PT	POINT OF TANGENCY
DIA	DIAMETER	PVC	POLYVINYL CHLORIDE PIPE
DMH	DRAINAGE MANHOLE	R	RADIUS
E	EASTING	RAD	RADIUS
EL	ELEVATION	RCP	REINFORCED CONCRETE PIPE
ELEV	ELEVATION	SD	STORM DRAIN
EMH	ELECTRIC MANHOLE	SDMH	STORM DRAIN MANHOLE
EOP	EDGE OF PAVEMENT	SESC	SOIL EROSION AND SEDIMENT CONTROL
EXP	EXPANSION	SS	SANITARY SEWER
EXIST	EXISTING	SSMH	SANITARY SEWER MANHOLE
G	GAS	SSFM	SANITARY SEWER FORCE MAIN
GALV	GALVANIZED	SQ FT	SQUARE FOOT
GALV	GRATE	SQ M	SQUARE METER
		TYP	TYPICAL
HDPE	CORRUGATED HIGH DENSITY POLYETHYLENE PIPE	TW	TOP OF WALL
HT INIV	HEIGHT	UC	UNDERGROUND COMMUNICATION
INV	INVERT	UD	UNDERDRAIN
			-
		UE	UNDERGROUND ELECTRICAL
		UG	UNDERGROUND
		UP	UTILITY POLE
		VC	VITRIFIED CLAY PIPE

WITHOUT



This document has been digitally sealed. Oct 5 2015

FOR PERMITTING **PURPOSES ONLY**

NOT FOR CONSTRUCTION

NPTT502-G00

SHEET 2 OF 19

ES: RLR | CHK:JJ: RW: KRB | APR: BS

FRANKLIN,N

RANSMISSION LIN


IILE NO:

ransmissio

Business

I KLIN NOTE

FRAN! GENERAL 1



- REFER TO SHEET NPTT502-G001 FOR ADDITIONAL GENERAL NOTES, ABBREVIATIONS, AND LEGENDS.
- 2. THE STATION ELECTRICAL EQUIPMENT, ENCLOSURES, FOUNDATIONS, OTHER STATION APPURTENANCES, OVERHEAD TRANSMISSION, AND UNDERGROUND TRANSMISSION ARE SHOWN FOR REFERENCE ONLY.
- 3. THIS DRAWING IS INTENDED TO DEPICT SITE LAYOUT ONLY.
- 4. CONTRACTOR SHALL TAKE PRECAUTIONS TO ENSURE NO DISTURBANCE BEYOND DEPICTED LIMIT OF NPDES/LIMIT OF DISTURBANCE.
- 5. NEW HAMPSHIRE STATE PLANE COORDINATE SYSTEM HORIZONTAL DATUM NAD83
 VERTICAL DATUM NAVD88
- 6. UPON COMPLETION OF SITE CLEARING, THE CONTRACTOR SHALL FURNISH AND INSTALL PERMANENT BENCHMARKS IN THE LOCATIONS DEPICTED ON THE PLANS IN ACCORDANCE WITH THE STATE OF NEW HAMPSHIRE SURVEYING CODES AND STANDARDS. BENCHMARK ELEVATIONS SHALL BE SET IN FIELD AND VERIFIED PRIOR TO START OF
- 7. CONTRACTOR SHALL INSTALL GUIDERAIL SYSTEMS AS DEPICTED IN ACCORDANCE WITH NEW HAMPSHIRE DEPARTMENT OF TRANSPORTATION STANDARD SPECIFICATIONS AND STANDARD PLANS FOR THRIE BEAM SINGLE FACED GUIDERAIL WITH STEEL POSTS AND TERMINAL UNIT TYPE G-2. THIS END SECTION IS NOT CRASH WORTHY. IT IS INTENDED FOR USE PRIMARILY ON LOW SPEED ACCESS ROADS WHERE IT CAN NOT BE HIT.
- 8. OFFSITE ROADWAY (TOWN AND/OR STATE)
 IMPROVEMENTS AS A RESULT OF THE STATION
 DEVELOPMENT ARE NOT ANTICIPATED.

	POINT TABLE							
PNT	NORTHING	EASTING	DESCRIPTION					
1	325138.56	988610.55	CORNER OF PAD					
2	325142.78	988610.99	FENCE CORNER					
3	325531.21	988291.39	CORNER OF PAD					
4	325530.77	988295.61	FENCE CORNER					
5	326008.06	988878.03	CORNER OF PAD					
6	326003.84	988877.60	FENCE CORNER					
7	325997.97	988886.23	BEGIN ACCESS ROAD 1					
8	325894.48	988972.94	135' RAD PT TO CL OF ROAD 1					
9	325979.63	989077.69	ACCESS ROAD 1 - P.T.					
10	325955.36	989097.42	ACCESS ROAD 1 - P.C.					
11	326040.51	989202.18	135' RAD PT TO CL OF ROAD 1					
12	325961.65	989105.19	ACCESS ROAD 1 - END PAVIN					
13	325905.51	989202.18	ACCESS ROAD 1 - P.T.					
14	325905.51	989308.60	P.I. ACCESS ROADS 1 & 2					
15	325879.13	989233.53	ACCESS ROAD 2 - P.C.					
16	325785.51	989308.60	120' RAD PT TO CL OF ROAD 2					
17	325757.43	989081.76	ACCESS ROAD 2 - END PAVIN					
18	325747.33	989089.97	CORNER OF PAD					
19	325747.79	989085.72	FENCE CORNER					
20	325757.43	989081.76	BEGIN ACCESS ROAD 2					
21	325545.49	988841.65	CORNER OF PAD					
22	325545.93	988837.43	FENCE CORNER					
23	325413.57	988948.88	CORNER OF PAD					
24	325414.01	988944.66	FENCE CORNER					
25	325825.51	989555.77	70' RAD PT					
26	325840.12	989624.22	TIE INTO EXISTING ROAD					
27	325905.51	989616.78	TIE INTO EXISTING ROAD					
28	325985.51	989542.00	70' RAD PT					
29	325988.05	989611.96	TIE INTO EXISTING ROAD					
30	325848.72	989131.66	30' RAD PT					



This document has been digitally sealed. Oct 5 2015

FOR PERMITTING
PURPOSES ONLY
NOT FOR CONSTRUCTION


NPTT503-C100

MILE NO: SHEET 3 OF 19

TOWN:
FRANKLIN, N
TRANSMISSION LIN

Fransmissior Business

FRANKLIN STATION SITE LAYOUT PLAN



GRADING PLAN NOTES:

- 1. REFER TO SHEET NPTT502-G001 FOR ADDITIONAL GENERAL NOTES, ABBREVIATIONS, AND LEGENDS.
- 2. REFER TO SHEETS NPTT509-C300 AND NPTT510-C301 FOR GRADING CROSS SECTIONS.
- 3. NEW HAMPSHIRE STATE PLANE COORDINATE SYSTEM HORIZONTAL DATUM - NAD83 VERTICAL DATUM - NAVD88
- 4. PROPOSED CONTOURS AND SPOT ELEVATIONS INDICATED REFER TO TOP OF FINISH SURFACE.
- 5. ALL FILL AND CUT SLOPES ARE 3-FT HORIZONTAL TO 1-FT VERTICAL (3:1) UNLESS NOTED OTHERWISE.
- 6. CONTRACTOR SHALL PLACE 4" TOPSOIL AND SEED ON ALL CUT AND FILL SLOPES AS SPECIFIED UNLESS ANOTHER SURFACE MATERIAL IS INDICATED. EROSION CONTROL BLANKETS (NORTH AMERICAN GREEN SC250 OR ENGINEER APPROVED EQUAL) SHALL BE PLACED OVER ALL SEEDED SIDE SLOPES.
- AFTER COMPLETION OF YARD SUBGRADE WORK, THE SURFACE COURSE FOR THE STATION (INSIDE THE FENCE, 3-FT OUTSIDE THE FENCE, AND WHERE INDICATED ON THE PLANS) SHALL CONSIST OF A 4-INCH LAYER OF CRUSHED BASALT (ANGULAR STONE) STONE MEETING THE GRADATION REQUIREMENTS INDICATED IN THE SPECIFICATIONS.
- 8. CONTRACTOR SHALL PROTECT/REPAIR ALL SLOPES UNTIL FINAL VEGETATIVE OR STONE STABILIZATION.
- 9. ALL EXCAVATIONS SHALL BE THOROUGHLY SECURED AND STABILIZED ON A DAILY BASIS BY THE CONTRACTOR AT THE COMPLETION OF CONSTRUCTION OPERATIONS.
- 10. STABILIZE ALL DITCHES, SWALES, AND PONDS PRIOR TO DIRECTING STORMWATER RUNOFF TO THEM.
- 11. TURF REINFORCEMENT MAT (TRM) SHALL BE INSTALLED ON ALL 3-FT HORIZONTAL TO 1-FT VERTICAL SLOPES (3:1) OR STEEPER, AND BE NORTH AMERICAN GREEN SC250 OR APPROVED EQUAL.
- 12. EARTHWORK AND COMPACTION SHALL BE IN ACCORDANCE WITH THE RECOMMENDATIONS MADE IN THE GEOTECHNICAL ENGINEERING REPORT BY OTHERS.

	POINT TABLE							
PNT	NORTHING	EASTING	ELEV.	DESCRIPTION				
45	325937.21	989510.18	303.00	END DIVERSION (SW-6)				
46	325940.49	989530.16	301.00	DITCH CL (SW-6) - END				
47	325915.51	989541.93	303.27	ACCESS ROAD EDGE - P.C.				
48	325895.51	989541.93	303.27	ACCESS ROAD EDGE - P.C.				
49	325988.05	989611.96	300.37	TIE INTO EXISTING ROAD				
50	325905.51	989616.78	300.71	TIE INTO EXISTING ROAD				
51	325840.12	989624.22	301.81	TIE INTO EXISTING ROAD				
52	325868.62	989527.63	303.51	HIGH POINT				
53	325874.51	989531.11	302.00	DITCH CL (SW-5) - END				
54	325886.51	989462.16	307.79	DITCH CL (SW-5) - P.C.				
55	325773.48	989132.14	339.00	DITCH CL (SW-5) - BEGIN				
56	325760.68	989136.76	341.99	HIGH POINT				
57	325787.18	989079.22	337.24	DITCH CL (SW-3) - END				
58	325757.43	989081.76	342.50	ACCESS ROAD 2 CL - BEGIN				
59	325747.79	989085.72	342.53	FENCE CORNER				
60	325747.33	989089.97	342.50	CORNER OF PAD				
61	325724.44	989131.69	336.83	DITCH CL (SW-4) - BEGIN				
62	325639.68	989224.68	338.40	EDGE OF BERM				
63	325628.51	989211.87	336.20	DITCH CL (SW-4) - P.C.				
64	325615.27	989197.02	342.50	EDGE OF LEVEL GRADE				
65	325595.23	989228.25	338.27	EDGE OF BERM				
66	325604.21	989213.82	336.07	DITCH CL (SW-4) - P.T.				
67	325533.76	989190.01	334.73	EDGE OF BERM				
68	325524.89	989164.46	331.50	DITCH CL (SW-4) - END				
69	325545.93	988837.43	345.67	FENCE CORNER				
70	325545.49	988841.65	345.70	CORNER OF PAD				
71	325414.01	988944.66	345.67	FENCE CORNER				
72	325413.57	988948.88	345.70	CORNER OF PAD				



This document has been digitally sealed.

FOR PERMITTING PURPOSES ONLY NOT FOR CONSTRUCTION


Business FRANKLIN GRADING DES: RLR CHK:JJ DRW: KRB APR: B

SHEET 4 OF 19


TOWN: FRANKLIN,

RANSMISSION LIN

MILE NO:



REVISION: XXX



PLANTING PLAN NOTES:

REFER TO SHEET NPTT502-G001 FOR ADDITIONAL GENERAL NOTES, ABBREVIATIONS, AND LEGENDS.

2. THIS DRAWING IS INTENDED TO DESCRIBE LANDSCAPE INFORMATION

3. ALL DISTURBED AREAS NOT OTHERWISE DEVELOPED SHALL HAVE A MINIMUM OF 4" OF LOAM AND THE FOLLOWING SEED MIXTURE:

NHDOT TYPE 44 (MIN. 80 LBS/ACRE):

44% CREEPING RED FESCUE (MIN. 35 LBS/ACRE)

38% PERENNIAL RYEGRASS (MIN. 30 LBS/ACRE) 6% REDTOP (MIN. 5 LBS/ACRE)

6% ALSIKE CLOVER (MIN. 5 LBS/ACRE)

6% BIRDSFOOT TREFOIL (MIN. 5 LBS/ACRE) ALL SEEDING SHALL BE IN ACCORDANCE WITH THE NEW HAMPSHIRE DEPARTMENT OF TRANSPORTATION STANDARD SPECIFICATIONS (2010) SECTION 644 -- GRASS SEED AND THE NEW HAMPSHIRE DEPARTMENT OF ENVIRONMENTAL SERVICES STORMWATER MANUAL VOLUME 3

NO SEEDING SHALL BE PLACED BEFORE ROUGH GRADING HAS BEEN PROPERLY COMPLETED.

TOPSOIL SHALL BE INSTALLED AT A MINIMUM DEPTH OF 4". CONTRACTOR SHALL SUBMIT SAMPLES FROM EACH PROPOSED TOPSOIL SOURCE TO A CERTIFIED TESTING LABORATORY TO DETERMINE pH, FERTILITY, ORGANIC CONTENT AND MECHANICAL COMPOSITION. CONTRACTOR SHALL SUBMIT THE TEST RESULTS TO OWNER OR LANDSCAPE ARCHITECT FOR REVIEW. CONTRACTOR SHALL INCORPORATE AMENDMENTS FOR PROPER SOIL pH AND PLANT GROWTH AS RECOMMENDED BY TEST REPORTS AT NO INCREASE IN CONTRACT PRICE.

6. TEMPORARY AND PERMANENT SEEDING SHALL SHALL BE IN ACCORDANCE WITH THE PLANTING PLAN, NH DES STORMWATER MANUAL VOLUME 3, AND NH DOT STANDARD SPECIFICATIONS SECTION 644.

AREAS WHICH ARE TO BE TOPSOILED SHALL BE SCARIFIED TO A MINIMUM DEPTH OF 3 TO 5 INCHES -- 6 TO 12 INCHES ON COMPACTED SOILS -- PRIOR TO PLACEMENT OF TOPSOIL. AREAS TO BE VEGETATED SHALL HAVE A MINIMUM 4 INCHES OF TOPSOIL IN PLACE PRIOR TO SEEDING AND


PLACING LOAM ON SITE: ALL SUBGRADE ELEVATIONS SHOULD BE UNIFORMLY GRADED TO RECEIVE LOAM AND SHALL BE INSPECTED AND APPROVED BY THE GENERAL CONTRACTOR PRIOR TO PLACEMENT OF LOAM. PLACE LOAM TO FORM A MINIMUM DEPTH OF 4" WHEN ROLLED, UNLESS OTHERWISE INDICATED. ALL DEPRESSIONS EXPOSED DURING THE ROLLING SHALL BE FILLED WITH ADDITIONAL LOAM.

SEED BED PREPARATION: AFTER FINISH GRADING AND JUST BEFORE SEEDING, THE AREAS TO BE SEEDED SHALL BE LOOSENED TO PROVIDE A ROUGH, FIRM BUT FINELY PULVERIZED SEEDBED. THE INTENT IS A TEXTURE CAPABLE OF RETAINING WATER, SEED AND FERTILIZER WHILE REMAINING STABLE AND ALLOWING SEED TIME TO GERMINATE. SEED SHALL BE APPLIED TO THE CONDITIONED SEEDBED NOT MORE THAN 48 HOURS AFTER THE SEEDBED HAS BEEN PREPARED.

10. LIME AND FERTILIZER SHALL BE INCORPORATED INTO THE SOIL PRIOR TO OR AT THE TIME OF AT THE TIME OF SEEDING. A MINIMUM OF 2 TONS PER ACRE OF AGRICULTURAL LIMESTONE AND 500 LBS. PER ACRE OF 10-20-20 FERTILIZER SHALL BE APPLIED. SEEDING PRACTICES SHALL COMPLY WITH LOCAL USDA SOIL CONSERVATION SERVICES RECOMMENDATIONS.

11. STRAW MULCH OR JUTE MATTING SHALL BE USED WHERE INDICATED ON THE PLANS. A MINIMUM OF 1.5 TONS OF MULCH PER ACRE SHALL BE APPLIED. MULCH SHALL BE ANCHORED IN PLACE WHERE NECESSARY. JUTE MATTING SHALL BE LAID IN THE DIRECTION OF RUNOFF FLOW AND APPLIED IN ACCORDANCE WITH MANUFACTURER'S INSTRUCTIONS.


12. PERMANENT OR TEMPORARY COVER MUST BE IN PLACE BEFORE THE GROWING SEASON ENDS. WHEN SEEDED AREAS ARE MULCHED, PLANTINGS MAY BE MADE FROM EARLY SPRING TO EARLY OCTOBER. WHEN SEEDED AREAS AREA NOT MULCHED, PLANTINGS SHOULD BE MADE FROM EARLY SPRING TO MAY 20 OR FROM AUGUST 15 TO SEPTEMBER 15. NO DISTURBED AREA SHALL BE LEFT EXPOSED DURING WINTER MONTHS.



SEED/MULCH COVER




BITUMINOUS CONCRETE **PAVEMENT**




INFILTRATION SAND SUBBASE





SCALE IN FEET



This document has been digitally sealed.

FOR PERMITTING **PURPOSES ONLY** NOT FOR CONSTRUCTION

Business


STATIO

RANKLIN S PLANTING

TOWN: FRANKLIN, I RANSMISSION LIN IILE NO:

NPTT506-C10

HEET 6 OF 19



CONSTRUCTION GENERAL PERMIT

- THE OWNER, IN CONJUNCTION WITH THE CONTRACTOR (OPERATORS), NEEDS TO OBTAIN A CONSTRUCTION GENERAL PERMIT (CGP) FOR LARGE CONSTRUCTION ACTIVITIES (FIVE OR MORE ACRES) OR SMALL CONSTRUCTION ACTIVITIES (GREATER THAN ONE ACRE BUT LESS THAN FIVE ACRES) FROM THE ENVIRONMENTAL PROTECTION AGENCY (EPA) AS PART OF THE CGP, A STORMWATER NOTICE OF INTENT (NOI) WILL NEED TO BE SUBMITTED TO THE EPA AT LEAST 7 DAYS PRIOR TO COMMENCING CONSTRUCTION. THE NOI WILL NEED TO BE SUBMITTED TO STORMWATER NOTICE OF INTENT(4203M) USEPA, 1200 PENNSYLVANIA AVE. NW. WASHINGTON, DC 20460.
- THE CGP OUTLINES A SET OF PROVISIONS MANDATING THE OWNER AND CONTRACTOR TO COMPLY WITH THE REQUIREMENTS OF THE NATIONAL POLLUTION DISCHARGE ELIMINATION SYSTEM (NPDES) STORMWATER REGULATIONS, INCLUDING, BUT NOT LIMITED TO, STORMWATER POLLUTION PREVENTION PLANS (SWPPP'S) IMPLEMENTATION OF EROSION AND SEDIMENTATION CONTROLS, EQUIPMENT MAINTENANCE GUIDELINES, ETC PLEASE CONTACT USEPA OFFICE OF WASTEWATER MANAGEMENT AT 202-564-9545 OR AT WWW.EPA.COV/NPDES/STORMWATER FOR ADDITIONAL INFORMATION. IN ADDITION ONE CAN CONTACT ABBY SWAIN OF NEW ENGLAND'S EPA REGION 1 AT 617-918-1841.

STORMWATER SYSTEM PLAN NOTES

- REFER TO SHEET NPTT502-G001 FOR ADDITIONAL GENERAL NOTES, ABBREVIATIONS, AND LEGENDS.
- THIS DRAWING IS INTENDED TO DESCRIBE THE STORMWATER SYSTEM ONLY
- NEW HAMPSHIRE STATE PLANE COORDINATE SYSTEM **HORIZONTAL DATUM - NAD83 VERTICAL DATUM - NAVD88**
- 4. STORM DRAINAGE SYSTEM CONNECTIONS, MATERIALS, AND METHODS SHALI BE IN ACCORDANCE WITH THE NH DOT STANDARDS AND NH DOT SPECIFICATION SECTIONS 603 AND 604, AS WELL AS OTHER APPLICABLE INDUSTRY CODES AND GOVERNING AGENCY REQUIREMENTS.
- THE CONTRACTOR SHALL VISIT THE SITE AND VERIFY THE ELEVATION AND LOCATION OF ALL UTILITIES BY VARIOUS MEANS PRIOR TO BEGINNING ANY EXCAVATION. TEST PITS SHALL BE DUG AT ALL LOCATIONS WHERE PROPOSED STORM PIPING WILL CROSS EXISTING UTILITIES, AND THE HORIZONTAL AND VERTICAL LOCATIONS OF THE UTILITIES SHALL BE DETERMINED. THE CONTRACTOR SHALL CONTACT THE ENGINEER IN THE EVENT OF ANY DISCOVERED OR UNFORESEEN CONFLICTS BETWEEN EXISTING AND PROPOSED SANITARY SEWERS, STORM PIPING AND UTILITIES SO THAT AN APPROPRIATE MODIFICATION MAY BE MADE.
- MANHOLE RIMS AND OUTLET CONTROL STRUCTURE GRATES SHALL BE SET TO ELEVATIONS SHOWN. SET ALL EXISTING MANHOLE RIMS, GRATES AND OTHER UTILITY TOPS TO BE RAISED OR LOWERED FLUSH WITH FINAL GRADE AS NECESSARY.
- THE CONTRACTOR SHALL ARRANGE FOR AND COORDINATE WITH APPLICABLE REGULATORY AGENCIES FOR STORM DRAINAGE INSTALLATIONS AND CONNECTIONS.
- THE CONTRACTOR SHALL COORDINATE WORK TO BE PERFORMED BY THE VARIOUS UTILITY PROVIDERS AND SHALL PAY ALL FEES FOR CONNECTIONS, DISCONNECTIONS, RELOCATIONS, INSPECTIONS, AND DEMOLITION UNLESS OTHERWISE STATED IN THE PROJECT SPECIFICATIONS MANUAL AND/OR GENERAL CONDITIONS OF THE CONTRACT.
- 9. ALL PIPES SHALL BE LAID ON STRAIGHT ALIGNMENTS AND EVEN GRADES USING A PIPE LASER OR OTHER ACCURATE METHOD.
- 10. ALL UTILITY CONSTRUCTION IS SUBJECT TO INSPECTION FOR APPROVAL PRIOR TO BACKFILLING, IN ACCORDANCE WITH THE APPROPRIATE OWNER, UTILITY PROVIDER, AND APPLICABLE REGULATORY AGENCY REQUIREMENTS
- A ONE-FOOT MINIMUM VERTICAL CLEARANCE BETWEEN ELECTRICAL AND TELEPHONE LINES TO STORM PIPING SHALL BE PROVIDED.
- 12. SITE CONTRACTOR SHALL PROVIDE ALL BENDS, FITTINGS, ADAPTERS, ETC., AS REQUIRED FOR PIPE CONNECTIONS.
- 13. THE CONTRACTOR SHALL MAINTAIN ALL FLOWS AND UTILITY CONNECTIONS WITHOUT INTERRUPTION UNLESS/UNTIL AUTHORIZED BY THE OWNER, THE ENGINEER, UTILITY PROVIDERS AND GOVERNING AUTHORITIES.
- 14. STORM DRAINAGE SHALL BE RATED FOR HS-20 LOADING
- LAY UNDERDRAINS BELOW CABLE TRENCH AS SPECIFIED. PROVIDE A MINIMUM 0.5% SLOPE ON ALL UNDERDRAINS. ADDITIONAL UNDERDRAINS MAY BE REQUIRED AS DEEMED NECESSARY BY THE OWNER, GEOTECHNICAL ENGINEER AND/OR ENGINEER BASED ON FINDINGS AFTER EARTHWORK AND EXCAVATION OPERATIONS COMMENCE. PROVIDE CLEANOUTS AT A MINIMUM OF EVERY 200' OF PIPE OR ONE CLEANOUT PER PIPE RUN WHERE THE PIPE RUN IN LESS THAN 200'.



This document has been digitally sealed. Oct 5 2015

FOR PERMITTING **PURPOSES ONLY** NOT FOR CONSTRUCTION

MILE NO: SHEET 7 OF 19 NPTT507-C10


RW: KRB APR: B


FRANKLIN,

RANSMISSION LIN


<u>FRANKLII</u> FORMWATER

Business





ACCESS ROAD 2 PROFILE





- 1. REFER TO SHEET NPTT502-G001 FOR ADDITIONAL GENERAL NOTES, ABBREVIATIONS, AND LEGENDS.
- 2. THIS DRAWING IS INTENDED TO DESCRIBE THE STATION ACCESS ROAD GEOMETRY ONLY.
- 3. NEW HAMPSHIRE STATE PLANE COORDINATE SYSTEM HORIZONTAL DATUM - NAD83 VERTICAL DATUM - NAVD88
- 4. PROPOSED CONTOURS AND SPOT ELEVATIONS INDICATED REFER TO TOP OF FINISH SURFACE.

Transmissior Business

FRANKLIN STATION ACCESS ROAD PROFILES

This document has been digitally sealed. Oct 5 2015

FOR PERMITTING **PURPOSES ONLY** NOT FOR CONSTRUCTION


NPTT508-C200

MILE NO: SHEET 8 OF 19

DES: RLR | CHK:JJS DRW: KRB | APR: BS


TOWN: FRANKLIN, N

RANSMISSION LINE



GRADING CROSS SECTION NOTES:

- 1. REFER TO SHEET NPTT502-G001 FOR ADDITIONAL GENERAL NOTES, ABBREVIATIONS, AND LEGENDS.
- 2. THIS DRAWING IS INTENDED TO DESCRIBE THE GRADING CROSS SECTIONS ONLY.
- 3. NEW HAMPSHIRE STATE PLANE COORDINATE **HORIZONTAL DATUM - NAD83** VERTICAL DATUM - NAVD88
- 4. PROPOSED CONTOURS AND SPOT ELEVATIONS INDICATED REFER TO TOP OF FINISH SURFACE.
- 5. CONTRACTOR SHALL PLACE 4" TOPSOIL AND SEED ON ALL CUT AND FILL SLOPES AS SPECIFIED UNLESS ANOTHER SURFACE MATERIAL IS INDICATED.
- 6. EARTHWORK AND COMPACTION SHALL BE IN ACCORDANCE WITH THE RECOMMENDATIONS MADE IN THE GEOTECHNICAL ENGINEERING RECOMMENDATIONS REPORT BY OTHERS.
- 7. STRIP AND STOCKPILE EXISTING TOPSOIL IN AREAS OF PROPOSED GRADING AND EARTHWORK.



Business

STATION SECTIONS


FRANKLIN SITE CROSS

TOWN: FRANKLIN, RANSMISSION LINE MILE NO: SHEET 9 OF 19

FOR PERMITTING PURPOSES ONLY NOT FOR CONSTRUCTION


SCALE IN FEET

VERT:



GRADING CROSS SECTION NOTES:

- 1. REFER TO SHEET NPTT502-G001 FOR ADDITIONAL GENERAL NOTES, ABBREVIATIONS, AND LEGENDS.
- 2. THIS DRAWING IS INTENDED TO DESCRIBE THE GRADING CROSS SECTIONS ONLY.
- 3. NEW HAMPSHIRE STATE PLANE COORDINATE HORIZONTAL DATUM - NAD83 VERTICAL DATUM - NAVD88
- 4. PROPOSED CONTOURS AND SPOT ELEVATIONS INDICATED REFER TO TOP OF FINISH SURFACE.
- 5. CONTRACTOR SHALL PLACE 4" TOPSOIL AND SEED ON ALL CUT AND FILL SLOPES AS SPECIFIED UNLESS ANOTHER SURFACE MATERIAL IS INDICATED.
- 6. EARTHWORK AND COMPACTION SHALL BE IN ACCORDANCE WITH THE RECOMMENDATIONS MADE IN THE GEOTECHNICAL ENGINEERING RECOMMENDATIONS REPORT BY OTHERS.
- 7. STRIP AND STOCKPILE EXISTING TOPSOIL IN AREAS OF PROPOSED GRADING AND EARTHWORK.



Fransmissior Business

FRANKLIN STATION SITE CROSS SECTIONS

TOWN: FRANKLIN, I RANSMISSION LINE

FOR PERMITTING **PURPOSES ONLY** NOT FOR CONSTRUCTION

This document has been digitally sealed. Oct 5 2015

EROSION AND SEDIMENTATION CONTROL GENERAL NOTES:

- 1. THE SEDIMENT AND EROSION CONTROL PLAN IS ONLY INTENDED TO DESCRIBE THE SEDIMENT AND EROSION CONTROL TREATMENT FOR THIS SITE. SEE SEDIMENT AND EROSION CONTROL DETAILS AND CONSTRUCTION SEQUENCE. REFER TO SITE PLAN FOR GENERAL INFORMATION AND OTHER CONTRACT PLANS FOR APPROPRIATE INFORMATION.
- 2. CONSTRUCTION ACTIVITIES SHALL PROCEED IN ACCORDANCE WITH THE GENERAL NOTES, SEQUENCE PROVIDED ON THE PLAN DRAWINGS. DEVIATION FROM THAT SEQUENCE MUST BE APPROVED IN WRITING BY THE OWNER, QUALIFIED PROFESSIONAL, AND APPROPRIATE REGULATORY AGENCY PRIOR TO IMPLEMENTATION.
- 3. THE EROSION AND SEDIMENTATION CONTROL MEASURES, CONSTRUCTION SEQUENCE AND PHASING IS THE MINIMUM RECOMMENDED. THE CONTRACTOR SHALL INSTALL AND MAINTAIN ADDITIONAL MEASURES AND SEQUENCING AS REQUIRED BASED ON ACTUAL FIELD OPERATIONS AND CONDITIONS AND BE CONSISTENT WITH THE NEW HAMPSHIRE STORMWATER MANUAL. SIGNIFICANT ADDITIONS AND/OR MODIFICATIONS FROM THE PLANS SHALL BE SUBMITTED, REVIEWED AND APPROVED BY THE OWNER, QUALIFIED PROFESSIONAL AND APPLICABLE REGULATORY AGENCIES.
- 4. THE SEDIMENT AND EROSION CONTROL PLAN WAS DEVELOPED TO HELP PROTECT THE EXISTING ROADWAY AND STORM DRAINAGE SYSTEMS. ADJACENT PROPERTIES, AND ADJACENT WETLAND AREA FROM SEDIMENT LADEN SURFACE RUNOFF AND EROSION.
- 5. APPROPRIATE EROSION/SEDIMENT CONTROL MEASURES AS DESCRIBED HEREIN, SHALL BE INSTALLED BY THE CONTRACTOR PRIOR TO THE COMMENCEMENT OF ALL CLEARING, DEMOLITION AND CONSTRUCTION ACTIVITY WITHIN THE APPROVED LIMITS OF DISTURBANCE. SCHEDULE WORK TO MINIMIZE THE LENGTH OF TIME THAT BARE SOIL WILL BE EXPOSED. CONTRACTOR SHALL ONLY EXCAVATE AS MUCH UTILITY AND STORM PIPE TRENCH WORK AS CAN BE COMPLETED, BACKFILLED AND STABILIZED IN ONE DAY SO AS TO LIMIT THE AMOUNT OF OPEN, DISTURBED TRENCHING. THE SMALLEST PRACTICAL AREA SHALL BE DISTURBED DURING CONSTRUCTION, BUT IN NO CASE SHALL EXCEED 5 ACRES AT ANY ONE TIME BEFORE DISTURBED AREAS ARE STABILIZED
- 6. THE CONTRACTOR SHALL INSTALL ALL SPECIFIED EROSION/SEDIMENT CONTROL MEASURES AND WILL BE REQUIRED TO MAINTAIN THEM IN THEIR INTENDED FUNCTIONING CONDITION AND BE IN STRICT CONFORMANCE WITH THE STANDARDS BELOW. THE CONTRACTOR SHALL SUPPLY AND MAINTAIN THESE STANDARDS AND HAVE THEM AVAILABLE ONSITE FOR THE DURATION OF CONSTRUCTION. THE OWNER, AGENTS OF THE REGULATORY AGENCIES AND/OR QUALIFIED PROFESSIONAL SHALL HAVE THE AUTHORITY TO REQUIRE SUPPLEMENTAL MAINTENANCE OR ADDITIONAL MEASURES IF FIELD CONDITIONS ARE ENCOUNTERED BEYOND WHAT WOULD NORMALLY BE ANTICIPATED.
 - A. EVERSOURCE BEST MANAGEMENT PRACTICES MANUAL (TO BE FURTHER DEVELOPED).
- B. NEW HAMPSHIRE DEPARTMENT OF ENVIRONMENTAL SERVICES STORMWATER MANUAL, DECEMBER 2008.
- IMMEDIATELY UPON DISCOVERING UNFORESEEN CIRCUMSTANCES POSING THE POTENTIAL FOR ACCELERATED EROSION AND/OR SEDIMENT POLLUTION, THE CONTRACTOR SHALL IMPLEMENT APPROPRIATE BEST MANAGEMENT PRACTICES TO ELIMINATE THE POTENTIAL FOR ACCELERATED EROSION AND/OR SEDIMENT POLLUTION.
- 8. THE CONTRACTOR SHALL KEEP A SUPPLY OF EROSION CONTROL MATERIAL (STRAW BALES, SILT FENCE, JUTE MESH, RIP RAP ETC.) ON-SITE FOR MAINTENANCE AND EMERGENCY REPAIRS.
- 9. STONE CONSTRUCTION ENTRANCE/EXIT SHALL BE INSTALLED AT START OF CONSTRUCTION AND MAINTAINED THROUGHOUT THE DURATION OF CONSTRUCTION. THE LOCATION OF THE TRACKING PADS MAY CHANGE AS VARIOUS PHASES OF CONSTRUCTION ARE COMPLETED
- 10. TOPSOIL SHALL BE STRIPPED AND STOCKPILED FOR USE IN FINAL LANDSCAPING. ALL EARTH STOCKPILES SHALL HAVE STRAW BALES OR SILT FENCE AROUND THE LIMIT OF PILE. PILES SHALL BE TEMPORARILY SEEDED IF PILE IS TO REMAIN IN PLACE FOR MORE THAN 2 MONTHS.
- 11. COMPLY WITH REQUIREMENTS OF THE EPA FOR NPDES AND RECORD KEEPING.
- 12. VISUAL SITE INSPECTIONS SHALL BE CONDUCTED WEEKLY, AND AFTER EACH MEASURABLE PRECIPITATION EVENT OF 0.50 INCHES OR GREATER BY QUALIFIED PERSONNEL, TRAINED AND EXPERIENCED IN EROSION AND SEDIMENT CONTROL, TO ASCERTAIN THAT THE EROSION AND SEDIMENT CONTROL (E&S) BMPS ARE OPERATIONAL AND EFFECTIVE IN PREVENTING POLLUTION. PROVIDE WRITTEN REPORTS IN ACCORDANCE WITH ANY APPLICABLE OWNER, QUALIFIED PROFESSIONAL, AND/OR REGULATORY AGENCY REQUIREMENTS.
- 13. STOCKPILES OF EARTH MATERIALS SHALL CONFORM TO SOIL STOCKPILE PRACTICES IN SECTION 4.1 OF THE NH DES STORMWATER MANUAL VOLUME 3.
- 14. DEWATERING SUMP PITS SHALL BE INSTALLED WHEN WATER COLLECTS DURING DURING EXCAVATION TO TRAP AND FILTER WATER FOR PUMPING INTO A SUITABLE DISCHARGE AREA. A PERFORATED VERTICAL STANDPIPE WRAPPED IN NON-WOVEN FILTER FABRIC IS PLACED IN THE CENTER OF THE PIT TO COLLECT FILTERED WATER WHERE IT IS THEN REMOVED FROM THE SUMP PIT IN AN AUTHORIZED MANNER. UNDER NO CIRCUMSTANCES SHALL DEWATERING DRAINAGE BE DISCHARGED INTO A SANITARY SEWER. CONSTRUCTION DEWATERING SHALL CONFORM TO CONSTRUCTION DEWATERING REQUIREMENTS OF THE NH DES STORMWATER MANUAL VOLUME 3 SECTION 4.2.
- 15. WATER SHALL BE USED FOR DUST CONTROL IN APPROPRIATE AREAS.

- 16. ALL REGULATORY AGENCY PERMITS REQUIRED FOR THE SITE SHALL BE OBTAINED PRIOR TO SITE WORK COMMENCES
- 17. ALL OFF-SITE WASTE AND BORROW AREAS MUST HAVE AN E&S PLAN APPROVED BY THE LOCAL CONSERVATION DISTRICT OR THE DEPARTMENT FULLY IMPLEMENTED PRIOR TO BEING ACTIVATED.
- 18. E&S BMPS SHALL REMAIN FUNCTIONAL AS SUCH UNTIL ALL AREAS TRIBUTARY TO THEM ARE PERMANENTLY STABILIZED OR UNTIL THEY ARE REPLACED BY ANOTHER BMP APPROVED BY THE LOCAL CONSERVATION DISTRICT OR THE DEPARTMENT.
- 19. MAXIMUM SLOPES SHALL NOT EXCEED 3-FT HORIZONTAL TO 1-FT VERTICAL (3:1), UNLESS OTHERWISE NOTED. THE CONTRACTOR SHALL VERIFY SLOPE STABILITY OF ALL SLOPES PRIOR TO CONSTRUCTION. UNSTABLE SLOPES SHALL BE LAID BACK (FLATTENED) UNTIL STABLE OR PROVIDE REINFORCING TO ACHIEVE STABILIZATION. SLOPE BENCHES SHALL BE IN ACCORDANCE WITH THE NHDES STORMWATER MANUAL.
- 20. THE CONTRACTOR SHALL MAINTAIN EMERGENCY ACCESS TO ALL AREAS AFFECTED BY HIS WORK AT ALL TIMES.
- 21. TEMPORARY AND PERMANENT SEEDING SHALL SHALL BE IN ACCORDANCE WITH THE PLANTING PLAN, NH DES STORMWATER MANUAL VOLUME 3, AND NH DOT STANDARD SPECIFICATIONS SECTION 644.

ALTERATION OF TERRAIN STANDARD NOTES:

- THE PROJECT IS TO BE MANAGED IN A MANNER THAT MEETS THE REQUIREMENTS AND INTENT OF RSA 430:53 AND CHAPTER AGR 3800 RELATIVE TO INVASIVE SPECIES.
- 2. PERIMETER CONTROLS SHALL BE INSTALLED PRIOR TO EARTH MOVING OPERATIONS. INSTALL TEMPORARY EROSION AND SEDIMENT CONTROL DEVICES AS NECESSARY PRIOR TO FURTHER EARTH MOVING OPERATIONS. PREVENTION OF EROSION AND SEDIMENT TRANSPORTATION ISSUES WILL BE FACILITATED BY THE PROMPT EMPLOYMENT OF EFFECTIVE TEMPORARY AND PERMANENT CONTROL DEVICES, AS CONDITIONS WARRANT. ADDITIONAL CONTROL DEVICES THAT ARE DETERMINED NECESSARY, NOT OUTLINED HEREIN, MAY BE INSTALLED BY THE OWNER OR OPERATOR.
- 3. PONDS AND SWALES SHALL BE INSTALLED EARLY ON IN THE CONSTRUCTION SEQUENCE PRIOR TO ROUGH GRADING THE SITE AND OTHER EARTH MOVING ACTIVITIES.
- 4. DITCHES AND SWALES SHALL BE STABILIZED PRIOR TO DIRECTING RUNOFF TO
- 5. ROADWAYS SHALL BE STABILIZED WITHIN 72 HOURS OF ACHIEVING FINISHED
- 6. CUT AND FILL SLOPES SHALL BE SEEDED/LOAMED WITHIN 72 HOURS OF ACHIEVING FINISHED GRADE.
- INSPECT AND MAINTAIN ALL EROSION AND SEDIMENTATION CONTROL MEASURES WEEKLY AND AFTER EVERY HALF-INCH OF RAINFALL DURING THE LIFE OF THE PROJECT. REMOVE TRAPPED SEDIMENT FROM COLLECTOR DEVICES AS NEEDED.
- 8. STABLE IS DEFINED AS:
 - A. BASE COURSE GRAVELS HAVE BEEN INSTALLED IN AREAS TO BE PAVED,
 - B. A MINIMUM OF 85 PERCENT VEGETATED GROWTH HAS BEEN ESTABLISHED,
 - C. A MINIMUM 3-INCHES OF NON-EROSIVE MATERIAL SUCH AS STONE OR RIPRAP HAS BEEN INSTALLED,
 - D. OR EROSION CONTROL BLANKETS HAVE BEEN PROPERLY INSTALLED.
- 9. ALL AREAS SHALL BE STABILIZED WITHIN 45 DAYS OF INITIAL DISTURBANCE.
- 10. TEMPORARY AND PERMANENT SEEDING SPECIFICATIONS ARE AS NOTED IN THE "VEGETATION MEASURES" SECTION ON THIS SHEET.
- 11. STANDARD WINTER NOTES:
 - A. ALL PROPOSED VEGETATED AREAS THAT DO NOT EXHIBIT A MINIMUM 85 PERCENT VEGETATIVE GROWTH BY OCTOBER 15, OR WHICH ARE DISTURBED AFTER OCTOBER 15, SHALL BE STABILIZED BY SEEDING AND INSTALLING EROSION CONTROL BLANKETS ON SLOPES GREATER THAN 3:1, AND SEEDING AND PLACING 3 TO 4 TONS OF MULCH PER ACRE, SECURED WITH ANCHORED NETTING, ELSEWHERE. THE INSTALLATION OF EROSION CONTROL BLANKETS OR MULCH AND NETTING SHALL NOT OCCUR OVER ACCUMULATED SNOW OR ON FROZEN GROUND AND SHALL BE COMPLETED IN ADVANCE OF THAW OR SPRING MELT EVENTS.
 - ALL DITCHES OR SWALES WHICH DO NOT EXHIBIT A MINIMUM OF 85 PERCENT VEGETATIVE GROWTH BY OCTOBER 15, OR WHICH ARE DISTURBED AFTER OCTOBER 15, SHALL BE STABILIZED TEMPORARILY WITH STONE OR EROSION CONTROL BLANKETS APPROPRIATE FOR THE DESIGN FLOW CONDITIONS.
 - C. AFTER NOVEMBER 15, INCOMPLETE ROAD OR PARKING SURFACES, WHERE WORK HAS STOPPED FOR THE WINTER SEASON, SHALL BE PROTECTED WITH A MINIMUM OF 3 INCHES OF CRUSHED GRAVEL PER NHDOT ITEM 304.3.

WINTER CONSTRUCTION NOTES:

- 1. WINTER EXCAVATION AND EARTHWORK SHALL BE COMPLETED AS SUCH THAT NO MORE THAN 1 ACRE OF THE SITE IS WITHOUT STABILIZATION AT ANY ONE TIME.
- 2. AN AREA WITHIN 100 FEET OF A PROTECTED NATURAL RESOURCE SHALL BE PROTECTED WITH A DOUBLE ROW OF SEDIMENT BARRIER.

- 3. TEMPORARY MULCH SHALL BE APPLIED WITHIN 7 DAYS OF SOIL EXPOSURE OR PRIOR TO ANY STORM EVENT. BUT AFTER EVERY WORKDAY IN AREAS WITHIN 100 FEET FROM A PROTECTED NATURAL RESOURCE.
- 4. AREAS THAT HAVE BEEN BROUGHT TO FINAL GRADE SHALL BE PERMANENTLY MULCHED THE SAME DAY.
- IN THE EVENT OF A SNOWFALL GREATER THAN 1 INCH (FRESH OR CUMULATIVE) THE SNOW SHALL BE REMOVED FROM THE AREAS DUE TO BE SEEDED AND MULCHED.
- 6. LOAM SHALL BE FREE OF FROZEN CLUMPS BEFORE IT IS APPLIED.
- 7. A DITCH THAT WILL BE CONSTRUCTED DURING THE WINTER MUST BE STABILIZED WITH RIPRAP.
- 8. PERMANENT STABILIZATION CONSISTS OF AT LEAST 85% VEGETATION, PAVEMENT/GRAVEL BASE OR RIPRAP.
- 9. DO NOT EXPOSE SLOPES OR LEAVE SLOPES EXPOSED OVER THE WINTER OR FOR ANY OTHER EXTENDED TIME OF WORK SUSPENSION UNLESS FULLY PROTECTED WITH MULCH AND EROSION CONTROLS.
- 10. APPLY STRAW MULCH AT TWICE THE STANDARD RATE (150 LBS. PER 1,000 SF). THE MULCH MUST BE THICK ENOUGH SUCH THAT THE GROUND SURFACE WILL NOT BE VISIBLE AND MUST BE ANCHORED.
- 11. USE MULCH AND MULCH NETTING OR AN EROSION CONTROL MULCH BLANKET OR MIX FOR ALL SLOPES GREATER THAN 8% OR OTHER AREAS EXPOSED TO DIRECT
- 12. INSTALL AN EROSION CONTROL BLANKET IN ALL DRAINAGE WAYS (BOTTOM AND SIDES) WITH A SLOPE GREATER THAN 3%.
- 13. SEE THE VEGETATION MEASURES FOR MORE INFORMATION ON SEEDING DATES AND TYPES.

CONSTRUCTION SEQUENCE:

THE FOLLOWING CONSTRUCTION SEQUENCE IS RECOMMENDED (COORDINATE ALL SITE ACTIVITIES AND CONSTRUCTION SEQUENCE WITH THAT OF THE STATION ELECTRICAL EQUIPMENT, OVERHEAD AND UNDERGROUND TRANSMISSION LINES, AND OTHER STATION RELATED CONSTRUCTION):

- 1. CONTACT THE OWNER, QUALIFIED PROFESSIONAL, AND REGULATORY AGENT AT LEAST FORTY-EIGHT (48) HOURS PRIOR TO COMMENCEMENT OF ANY DEMOLITION, CONSTRUCTION OR REGULATED ACTIVITY ON THIS PROJECT SITE.
- 2. CLEARING LIMITS SHALL BE PHYSICALLY MARKED IN THE FIELD AND APPROVED BY THE REGULATORY AGENT PRIOR TO THE START OF WORK ON THE SITE. INSTALL PERIMETER EROSION/SEDIMENT CONTROL MEASURES.
- 3. CONSTRUCT STONE CONSTRUCTION ENTRANCES/EXITS AND INSTALL INLET PROTECTION FOR CATCH BASINS OR INSTALL SILT SACKS ON CATCH BASIN INLETS LOCATED IN OFF-SITE ROADS. INSTALL SILT FENCE AND OTHER EROSION CONTROL DEVICES INDICATED ON THESE PLANS AT PERIMETER OF PROPOSED SITE DISTURBANCE AND INSTALL ALL EROSION/SEDIMENT CONTROL MEASURES AND TREE PROTECTION INDICATED ON THESE PLANS. INSTALL SEDIMENT BASINS AND SEDIMENT TRAPS IF REQUIRED AT LOW AREAS OF SITE OR AS ORDERED BY THE QUALIFIED PROFESSIONAL OR AS SHOWN ON THESE PLANS.
- 4. CLEAR AND GRUB SITE. STOCKPILE CHIPS. STOCKPILE TOPSOIL. INSTALL EROSION CONTROLS AT STOCKPILES.
- COMMENCE INSTALLATION OF STORM DRAINAGE SYSTEM.
- 6. COMMENCE EARTHWORK. CONSTRUCT FILL SLOPE. INSTALL ADDITIONAL EROSION CONTROLS AS WORK PROGRESSES AND CONTINUE STORM DRAINAGE SYSTEM CONSTRUCTION, TOPSOIL AND SEED SLOPES WHICH HAVE ACHIEVED FINAL SITE GRADING.
- 7. CONSTRUCTION STAKING OF ALL FOUNDATION CORNERS. UTILITIES. ACCESS DRIVES, FENCES AND OTHER SITE APPURTENANCES.
- 8. ROUGH GRADING AND FILLING OF SUBGRADES AND SLOPES.
- 9. BEFORE DISPOSING OF SOIL OR RECEIVING BORROW FOR THE SITE, THE CONTRACTOR MUST PROVIDE EVIDENCE THAT EACH SPOIL OR BORROW AREA HAS AN EROSION AND SEDIMENT CONTROL PLAN APPROVED BY THE APPROPRIATE REGULATORY AGENCIES AND WHICH IS BEING IMPLEMENTED AND MAINTAINED. THE CONTRACTOR SHALL ALSO NOTIFY THE APPROPRIATE REGULATORY AGENCIES IN WRITING OF ALL RECEIVING SPOIL AND BORROW AREAS WHEN THEY HAVE BEEN IDENTIFIED.
- 10. CONTINUE INSTALLATION OF STORM DRAINAGE AS SUBGRADE ELEVATIONS ARE ACHIEVED.
- 11. CONSTRUCT PAD SUBGRADE PREPARATION AND BEGIN FOUNDATION CONSTRUCTION.
- 12. THROUGHOUT CONSTRUCTION SEQUENCE, REMOVE SEDIMENT FROM BEHIND SILT FENCES, STRAW BALES AND OTHER EROSION CONTROL DEVICES, AND FROM SEDIMENT TRAPS AS REQUIRED. REMOVAL SHALL BE ON A PERIODIC BASIS (EVERY SIGNIFICANT RAINFALL OF 0.50 INCH OR GREATER). INSPECTION OF EROSION/SEDIMENT CONTROL MEASURES SHALL BE ON A WEEKLY BASIS AND AFTER EACH RAINFALL OF 0.50 INCHES OR GREATER. SEDIMENT COLLECTED SHALL BE DEPOSITED AND SPREAD EVENLY UPLAND ON SLOPES DURING CONSTRUCTION.

- 13. COMPLETE GRADING TO SUBGRADES AND COMPLETE CONSTRUCTION OF FOUNDATIONS.
- 14. CONSTRUCT PAVEMENT
- 15. CONDUCT FINE GRADING
- 16. PAVING OF ACCESS ROAD
- 17. CONSTRUCT OFF-SITE ROADWAY IMPROVEMENTS, AS NECESSARY
- 18. INSTALL YARD SURFACE STONE. FINAL FINE GRADING OF SLOPE AND NON-PAVED
- 19. PLACE 4" TOPSOIL ON SLOPES AFTER FINAL GRADING IS COMPLETED. FERTILIZE. SEED, AND MULCH.
- 20. LANDSCAPE INTERIOR NON-PAVED AREAS, NON-GRAVELED AREAS, AND PERIMETER AREAS.
- 21. INSTALL ON-SITE SIGNAGE AND PAVEMENT MARKINGS
- 22. CLEAN STORM DRAINAGE PIPE STRUCTURES, DETENTION SYSTEMS AND WATER QUALITY DEVICES OF DEBRIS AND SEDIMENT.
- 23. UPON DIRECTION OF THE OWNER, QUALIFIED PROFESSIONAL, AND REGULATORY AGENT, EROSION AND SEDIMENT CONTROL MEASURES SHALL BE REMOVED FOLLOWING STABILIZATION OF THE SITE.

ROUGH GRADING OPERATIONS

- 1. DURING THE REMOVAL AND/OR PLACEMENT OF EARTH AS INDICATED ON THE GRADING PLAN. TOPSOIL SHALL BE STRIPPED AND APPROPRIATELY STOCKPILED FOR REUSE.
- 2. ALL STOCKPILED TOPSOIL SHALL BE SEEDED, APPLY MULCH OR STRAW, AND **ENCLOSED BY A SILTATION FENCE.**

FILLING OPERATIONS


1. PRIOR TO FILLING, ALL SEDIMENTATION AND EROSION CONTROL DEVICES SHALL BE PROPERLY IMPLEMENTED, MAINTAINED AND FULLY INSTALLED, AS DIRECTED BY THE QUALIFIED PROFESSIONAL AND AS SHOWN ON THIS PLAN.

PLACEMENT OF DRAINAGE STRUCTURES, UTILITIES, AND FOUNDATION CONSTRUCTION OPERATIONS

1. SILT FENCES SHALL BE INSTALLED AT THE DOWNHILL SIDES OF EXCAVATIONS, MUD PUMP DISCHARGES, AND UTILITY TRENCH MATERIAL STOCKPILES. STRAW BALES MAY BE USED IF SHOWN ON THE EROSION CONTROL PLANS OR IF DIRECTED BY THE QUALIFIED PROFESSIONAL

FINAL GRADING AND PAVING OPERATIONS

- 1. ALL INLET AND OUTLET PROTECTION SHALL BE PLACED AND MAINTAINED AS SHOWN ON EROSION CONTROL PLANS AND DETAILS, AND AS DESCRIBED IN SPECIFICATIONS AND AS DESCRIBED HEREIN.
- 2. NO CUT OR FILL SLOPES SHALL EXCEED 2:1 EXCEPT WHERE STABILIZED BY ROCK FACED EMBANKMENTS OR EROSION CONTROL BLANKETS. JUTE MESH AND VEGETATION. ALL SLOPES SHALL BE SEEDED, AND ANY ROAD OR DRIVEWAY SHOULDER AND BANKS SHALL BE STABILIZED IMMEDIATELY UPON COMPLETION OF FINAL GRADING UNTIL TURF IS ESTABLISHED.
- 3. PAVEMENT SUB-BASE AND BASE COURSES SHALL BE INSTALLED OVER AREAS TO BE PAVED AS SOON AS FINAL SUB-GRADES ARE ESTABLISHED AND UNDERGROUND UTILITIES AND STORM DRAINAGE SYSTEMS HAVE BEEN INSTALLED.
- AFTER CONSTRUCTION OF PAVEMENT, TOPSOIL, FINAL SEED, MULCH AND LANDSCAPING, REMOVE ALL TEMPORARY EROSION CONTROL DEVICES ONLY AFTER ALL AREAS HAVE BEEN PAVED AND/OR GRASS HAS BEEN WELL ESTABLISHED AND THE SITE HAS BEEN INSPECTED AND APPROVED BY THE OWNER AND THE APPLICABLE REGULATORY AGENCIES.
- 5. AN AREA SHALL BE CONSIDERED TO HAVE ACHIEVED FINAL STABILIZATION WHEN IT HAS A MINIMUM OF 85% UNIFORM PERENNIAL VEGETATIVE COVER OR OTHER PERMANENT NON-VEGETATIVE COVER WITH A DENSITY SUFFICIENT TO RESIST ACCELERATED SURFACE EROSION AND SUBSURFACE CHARACTERISTICS SUFFICIENT TO RESIST SLIDING OR OTHER MOVEMENTS.
- MAINTAIN ALL PERMANENT AND TEMPORARY SEDIMENT CONTROL DEVICES IN EFFECTIVE CONDITION THROUGHOUT THE CONSTRUCTION PERIOD. UPON COMPLETION OF WORK SWEEP PARKING LOT AND REMOVE ALL TEMPORARY SEDIMENT CONTROLS WHEN AUTHORIZED BY LOCAL GOVERNING AUTHORITY. FILE NOT (NOTICE OF TERMINATION) WITH GOVERNING AUTHORITY RESPONSIBLE FOR REGULATING STORM WATER DISCHARGES FROM CONSTRUCTION ACTIVITIES PER NPDES.



This document has been digitally sealed.

Oct 5 2015

FOR PERMITTING **PURPOSES ONLY** NOT FOR CONSTRUCTION

IILE NO: SHEET 11 OF 19

NPTT511-C500


ransmissio Business

#

IUN ENT, ES


EROSION AND CONTRO

DES: RLR | CHK:JJ DRW: KRB | APR: B)WN: FRANKLIN, RANSMISSION LIN





- 2. WATER ALL SURFACE WATER FLOWING OR DIVERTED TOWARD CONSTRUCTION ENTRANCES SHALL BE PIPED ACROSS THE ENTRANCE. IF PIPING IS IMPRACTICAL, A MOUNTABLE BERM WITH 5:1 SLOPES WILL BE PERMITTED.
- 3. MAINTENANCE THE ENTRANCE SHALL BE MAINTAINED IN A CONDITION WHICH WILL PREVENT TRACKING OR FLOWING OF SEDIMENT ONTO PUBLIC RIGHTS-OF-WAY. THIS MAY REQUIRE PERIODIC TOP DRESSING WITH ADDITIONAL STONE AS CONDITIONS DEMAND AND REPAIR AND/OR CLEANOUT OF ANY MEASURES USED TO TRAP SEDIMENT. ALL SEDIMENT SPILLED, DROPPED, WASHED OR TRACKED ONTO PUBLIC RIGHTS-OF-WAY MUST BE REMOVED IMMEDIATELY.
- WASHING WHEELS SHALL BE CLEANED TO REMOVE SEDIMENT PRIOR TO ENTRANCE ONTO PUBLIC RIGHTS-OF-WAY. WHEN WASHING IS REQUIRED, IT SHALL BE DONE ON AN AREA STABILIZED WITH STONE AND WHICH DRAINS INTO AN APPROVED SEDIMENT TRAPPING DEVICE.
- 5. PERIODIC INSPECTION AND NEEDED MAINTENANCE SHALL BE PROVIDED AFTER EACH RAIN STORM EVENT.


STABILIZED





- 1. SILT SOCK SHALL BE FILTREXXTM SILTSOXXTM OR APPROVED EQUIVALENT.
- 2. SEE SPECIFICATIONS FOR SOCK SIZE AND COMPOST FILL REQUIREMENTS.
- 3. SILT SOCK SHALL BE INSPECTED PERIODICALLY AND AFTER ALL STORM EVENTS, AND REPAIR OR REPLACEMENT SHALL BE PERFORMED AS NEEDED.
- 4. COMPOST MATERIAL SHALL BE DISPERSED ON SITE, AS DETERMINED BY THE QUALIFIED PROFESSIONAL.











FLOW

NOTES:

C102

EROSION CONTROL BLANKET

NOT TO SCALE

- 1. ALL SLOPES 3:1 AND STEEPER SHALL RECEIVE EROSION CONTROL **BLANKET**
- 2. SEED AND SOIL AMENDMENTS SHALL BE APPLIED ACCORDING TO THE RATES IN THE PLAN DRAWINGS PRIOR TO INSTALLING THE BLANKET.
- 3. PROVIDE ANCHOR TRENCH AT TOE OF SLOPE IN SIMILAR FASHION AS AT TOP OF SLOPE.
- 4. SLOPE SURFACE SHALL BE FREE OF ROCKS, CLODS, STICKS, AND GRASS.
- 5. BLANKET SHALL HAVE GOOD CONTINUOUS CONTACT WITH UNDERLYING SOIL THROUGHOUT ENTIRE LENGTH. LAY BLANKET LOOSELY AND STAKE OR STAPLE TO MAINTAIN DIRECT CONTACT WITH SOIL. DO NOT STRETCH BLANKET.
- 6. THE BLANKET SHALL BE STAPLED IN ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATIONS.
- 7. BLANKETED AREAS SHALL BE INSPECTED WEEKLY AND AFTER EACH RUNOFF EVENT UNTIL PERENNIAL VEGETATION IS ESTABLISHED TO A MINIMUM UNIFORM 70% COVERAGE THROUGHOUT THE BLANKETED AREA. DAMAGED OR DISPLACED BLANKETS SHALL BE RESTORED OR REPLACED WITHIN 4 CALENDAR DAYS.



Oct 5 2015

FOR PERMITTING PURPOSES ONLY

AND MATERIAL REMOVED WHEN "BULGES" DEVELOP

POSTS: STEEL EITHER "T" OR "U"

TYPE OR 2" HARDWOOD.

6" MAX. MESH OPENING.

APPROVED EQUAL.

IN THE SILT FENCE.


This document has been digitally sealed.


NOT FOR CONSTRUCTION


ransmissio Business


DES: RLR CHK:JJ DRW: KRB APR: B TOWN: FRANKLIN, RANSMISSION LIN IILE NO:


SHEET 12 OF 19 NPTT512-C50
















FLARED END SECTION



PIPE TRENCH

NOT TO SCALE

C104



4" MIN. LOAM OR TOPSOIL AND SEED WITH EROSION CONTROL AND REVEGETATION MAT (ECRM) (EXCELSIOR, JUTE, MIRIMAT, OR EQUAL) OR SOD

NOTES

- 1. CHANNEL DIMENSIONS ARE FOR THE COMPLETED CHANNEL FINISH SURFACE GRADE.
- 2. INSTALL EROSION CONTROL BLANKET LINING TO TOP OF CHANNEL
- 3. INSTALL LINING PER MANUFACTURES SPECIFICATIONS AND RECOMMENDATIONS. SEED SLOPES PRIOR TO INSTALLATION PER MANUFACTURER RECOMMENDATIONS.
- 4. VEGETATED CHANNELS SHALL BE CONSTRUCTED FREE OF ROCKS, TREE ROOTS, STUMPS OR OTHER PROJECTIONS THAT WILL IMPEDE NORMAL CHANNEL FLOW AND/OR PREVENT GOOD LINING TO SOIL CONTACT. THE CHANNEL SHALL BE INITIALLY OVER-EXCAVATED TO ALLOW FOR THE PLACEMENT OF TOPSOIL.
- 5. ALL CHANNELS MUST BE KEPT FREE OF OBSTRUCTIONS SUCH AS FILL GROUND, FALLEN LEAVES AND WOODY DEBRIS, ACCUMULATED SEDIMENT, AND CONSTRUCTION MATERIALS/WASTES. CHANNELS SHOULD BE KEPT MOWED AND/OR FREE OF ALL WEEDY, BRUSHY OR WOODY GROWTH. ANY UNDERGROUND UTILITIES RUNNING ACROSS/THROUGH THE CHANNEL(S) SHALL BE IMMEDIATELY BACKFILLED AND THE CHANNEL(S) REPAIRED AND STABILIZED PER THE CHANNEL CROSS-SECTION DETAIL. DAMAGED LINING SHALL BE REPAIRED OR REPLACED WITHIN 48 HOURS OF DISCOVERY.

CHANNEL	LENGTH (FT.)	D	SIDE SLOPE Z ₁ Z ₂		SLOPE		LINING	STAPLE PATTERN	SLOPE (%)
SW-1	1,020	2	3	3	SC-250	E	0.50 - 0.70		
SW-2	122	2	3	3	SC-250	E	1.63		
SW-3	263	3	3	3	SC-250	E	0.50		
SW-4	245	3	3	3	SC-250	E	0.50 - 4.90		
SW-5	439	2	3	3	SC-250	E	7.75 - 8.25		
SW-6	680	2	3	3	SC-250	E	1.75 - 9.67		


GRASS SWALE CROSS SECTION NOT TO SCALE


			RIP RAP		RIP RAP APRON				
PIPE NO.	OUTLET NO.	PIPE DIA Pd (IN)	SIZE D ₅₀ =(IN)			INITIAL WIDTH Aiw (FT)	TERMINAL WIDTH Atw (FT)		
ST-2	RA-1	12"	6	18	8.0	3.0	11.0		
ST-3	RA-2	12"	6	18	8.0	2.0	11.0		
ST-4	RA-3	30"	9	27	24.0	2.0	32.0		
UD-3	RA-4	18"	9	27	16.0	2.0	20.0		
UD-6	RA-5	18"	9	27	16.0	2.0	21.0		
UD-9	RA-6	18"	6	18	14.0	2.0	18.0		

NOTES:

- 1. THE SUBGRADE FOR GEOTEXTILE FABRIC AND RIP-RAP SHALL BE PREPARED TO THE LINES AND GRADES SHOWN.
- 2. THE ROCK USED FOR RIP-RAP SHALL CONFORM TO NHDOT CLASS C STONE.
- 3. GEOTEXTILE FABRICS SHALL BE PROTECTED FROM PUNCTURE OR TEARING DURING THE PLACEMENT OF THE ROCK RIP-RAP. DAMAGED AREAS IN THE FABRIC SHALL BE PREPARED BY PLACING A PIECE OF FABRIC OVER THE DAMAGED AREA OR BY COMPLETE REPLACEMENT OF THE FABRIC. ALL OVERLAPS REQUIRED FOR REPAIRS OR JOINING TWO PIECES OF FABRIC SHALL BE A MINIMUM OF 12 INCHES.
- 4. STONE FOR THE RIP-RAP MAY BE PLACED BY EQUIPMENT AND SHALL BE CONSTRUCTED TO THE FULL LAYER THICKNESS IN ONE OPERATION AND IN SUCH A MANNER AS TO PREVENT SEGREGATION OF THE STONE SIZES.







1.	DESIGN OF END SECTION SHALL
	CONFORM TO STANDARD REINFORCED
	CONCRETE PIPE.

- 2. CUT OFF WALL TO BE POURED IN FIELD, IF NECESSARY, AS DIRECTED BY THE ENGINEER.
- 3. PAYMENT FOR THE CUT OFF WALL WILL BE MADE UNDER THE APPROPRIATE CONTRACT ITEMS.
- 4. PROVIDE ANIMAL BARRIER ON OUTLET. BARRIER SHALL NOT RESTRICT STORMWATER FLOW.

ITEM NO.	PIPE DIA.	APPROX. SLOPE X to Y	А	В	С	D	R	Т
603.30112	12"	3 TO 1	4"	24"	48 7/8"	24"	9"	2"
603.30130	30"	3 TO 1	12"	54"	19 3/4"	60"	15"	3 1/2"



This document has been digitally sealed. Oct 5 2015

FOR PERMITTING **PURPOSES ONLY**

END SECTION FOR RCP PIPE C104 NOT TO SCALE

NOT FOR CONSTRUCTION

SHEET 17 OF 19


TOWN: FRANKLIN, I RANSMISSION LIN

IILE NO:


ransmissio


Business

FRANKLIN STATION ONSTRUCTION DETAI



SPILLWAY WEIR									
BASIN NO.	Z3 (FT)	Z4 (FT)	TOP ELEV WTE (FT)	CREST ELEV WCE (FT)	WIDTH Ww (FT)	LINING	Z5 (FT)		
1	3	3	332.50	331.50	35	SC-250	4		
2	3	3	302.00	301.00	10	SC-250	160		







NOTES:

	STATION AND ACCESS ROAD SURFACE STONE GRADATION					
SIEVE	PERCENT BY WEIGHT PASSING SQUARE MESH SIEVE					
1-1/2 INCH	100					
1 INCH	93-100					
1/2 INCH	27-58					
1/4 INCH	0-8					


- 1. REMOVE ALL LOAM, CLAY, MUCK, STUMPS, AND OTHER IMPROPER ROAD FOUNDATION MATERIAL WITHIN 2' OF SUBGRADE. REPLACE WITH COMPACTED GRANULAR FILL MATERIAL ACCEPTABLE TO APPROVING AGENCY. COMPACTION TO BE AT LEAST 95% OF STANDARD PROCTOR.
- 2. STATION SURFACE STONE SHALL EXTEND 3-FT OUTSIDE THE STATION PERIMETER FENCE.
- 3. GRAVEL ACCESS ROAD SHALL HAVE AT LEAST 8 INCHES OF PROCESSED AGGREGATE BASE.












PAVEMENT AGGREGATE BASE STONE GRADATION					
SIEVE	PERCENT BY WEIGHT PASSING SQUARE MESH SIEVE				
2-1/2 INCH	100				
2 INCH	95-100				
3/4 INCH	50-75				
1/4 INCH	25-45				
NO. 40	5-20				
NO. 100	2-12				


ROAD CONSTRUCTION NOTES:

- REMOVE ALL LOAM, CLAY, MUCK, STUMPS, AND OTHER IMPROPER ROAD FOUNDATION MATERIAL WITHIN 2' OF SUBGRADE. REPLACE WITH COMPACTED GRANULAR FILL MATERIAL ACCEPTABLE TO APPROVING AGENCY. COMPACTION TO BE AT LEAST 95% OF STANDARD PROCTOR.
- 2. ALL PAVEMENT, BASE MATERIALS AND WORKMANSHIP TO BE IN COMPLIANCE WITH N.H.D.O.T. "STANDARDS FOR ROAD AND BRIDGE CONSTRUCTION" LATEST EDITION.








SPILLWAY



INFILTRATION BASIN 2 SEDIMENT FOREBAY DETAIL	3	
NOT TO SCALE	C104	









This document has been digitally sealed. Oct 5 2015

FOR PERMITTING **PURPOSES ONLY** NOT FOR CONSTRUCTION

NPTT518-C507

TOWN: FRANKLIN, N RANSMISSION LINE


MILE NO: SHEET 18 OF 19

Transmissior

Business

 \mathcal{O}

ERANKLIN STATION CONSTRUCTION DETAIL



141 11313-04